



Fire Department
 Fire and Life Safety
 505 Nutt St. Unit 1
 Wilmington, NC 28401
 910 343-0696
 910 341-0097 fax
 www.wilmingtonnc.gov
 Dial 711 TTY/Voice

UNDERGROUND FIRE LINE PERMIT APPLICATION

Business Name: _____ Site Address: _____

Property Owner: _____ Zip: _____ Phone: _____

Underground Contractor: _____ Address: _____

License: _____ Phone: _____ Fax: _____

Email: _____

Type of Pipe used: _____ Pipe Size: _____

Thrust Blocks: Yes___ No___ Joint Restraints: (Mega Lugs) Yes_____ No_____

Will Fire Hydrants be installed on the same Fire Line: Yes_____ No _____

If Clamps are used, Size of Clamps: _____

Are Restraint Straps Used for Tees? Yes_____ No_____ If So, Size_____

All plans submitted shall meet requirements in NFPA 24.

INSPECTIONS REQUIRED:

A Fire and Life Safety Inspector will be present to inspect piping before being covered. The inspector will also witness the hydrostatic testing and flushing of the piping. The flushing will be a minimum of 30 minutes time.

A 24-hour minimum notification to the Wilmington Fire and Life Safety Division is needed prior to any of the above required tests being performed. Any calls received after 3:00 PM the day prior to the anticipated test will not be scheduled on the following day's business. Contractor's Materials and Test Certificate for Underground Piping will be provided to the inspector at the completion of all required tests. All requirements shall be in the compliance of NFPA 13 and NFPA 24

Permit Fee of \$150.00 will be billed to you for all plans reviews and required inspections. **DO NOT SEND A CHECK WITH PERMIT APPLICATION.**